

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
13.07.1998	09:04	0.000	142.54	143.71
13.07.1998	09:05	0.000	142.54	
13.07.1998	09:05	0.010	142.37	
13.07.1998	09:06	0.010	141.75	
13.07.1998	09:07	0.010	141.72	
13.07.1998	09:08	0.010	141.63	
13.07.1998	09:09	0.010	141.54	
13.07.1998	09:10	0.010	141.46	
13.07.1998	09:11	0.010	141.39	
13.07.1998	09:12	0.010	141.32	
13.07.1998	09:13	0.010	141.25	
13.07.1998	09:14	0.010	141.19	
13.07.1998	09:15	0.010	141.12	
13.07.1998	09:17	0.010	141.03	
13.07.1998	09:19	0.010	140.92	
13.07.1998	09:21	0.010	140.83	
13.07.1998	09:23	0.010	140.73	
13.07.1998	09:25	0.010	140.64	
13.07.1998	09:30	0.010	140.5	
13.07.1998	09:35	0.010	140.3	
13.07.1998	09:40	0.010	140.13	
13.07.1998	09:45	0.010	139.97	
13.07.1998	09:55	0.010	139.75	
13.07.1998	10:05	0.010	139.49	
13.07.1998	10:15	0.010	139.26	
13.07.1998	10:25	0.010	139.05	
13.07.1998	10:35	0.010	138.84	
13.07.1998	11:05	0.010	138.03	
13.07.1998	12:05	0.010	137.6	
13.07.1998	13:05	0.010	137.02	
13.07.1998	14:05	0.010	136.33	
13.07.1998	15:05	0.010	135.73	
13.07.1998	16:05	0.010	135.18	
13.07.1998	17:05	0.010	134.69	
13.07.1998	18:05	0.010	134.21	
13.07.1998	19:05	0.010	133.75	
13.07.1998	20:05	0.010	133.33	135.48
13.07.1998	21:05	0.010	132.92	
13.07.1998	22:05	0.010	132.52	
13.07.1998	23:05	0.010	132.15	
14.07.1998	0:05	0.010	131.78	
14.07.1998	1:05	0.010	131.42	
14.07.1998	2:05	0.010	131.08	
14.07.1998	3:05	0.010	130.76	
14.07.1998	4:05	0.010	130.45	
14.07.1998	5:05	0.010	130.14	
14.07.1998	6:05	0.010	129.82	
14.07.1998	7:05	0.010	129.53	
14.07.1998	8:05	0.010	129.27	131.31
14.07.1998	9:05	0.010	129.01	130.83
14.07.1998	09:10	0.010	128.88	130.83
14.07.1998	09:10	0.000	128.88	130.83
14.07.1998	09:11	0.000	129.12	
14.07.1998	09:12	0.000	129.52	
14.07.1998	09:13	0.000	129.62	
14.07.1998	09:14	0.000	129.7	
14.07.1998	09:15	0.000	129.77	
14.07.1998	09:16	0.000	129.84	
14.07.1998	09:17	0.000	129.89	
14.07.1998	09:18	0.000	129.95	
14.07.1998	09:19	0.000	130	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
14.07.1998	09:20:00	0.000	130.05	
14.07.1998	09:21:00	0.000	130.10	
14.07.1998	09:23:00	0.000	130.17	
14.07.1998	09:25:00	0.000	130.27	
14.07.1998	09:27:00	0.000	130.35	
14.07.1998	09:29:00	0.000	130.44	
14.07.1998	09:31:00	0.000	130.52	
14.07.1998	09:36:00	0.000	130.64	
14.07.1998	09:41:00	0.000	130.80	
14.07.1998	09:46:00	0.000	130.95	
14.07.1998	09:51:00	0.000	131.09	
14.07.1998	10:01:00	0.000	131.28	
14.07.1998	10:11:00	0.000	131.51	
14.07.1998	10:21:00	0.000	131.72	
14.07.1998	10:31:00	0.000	131.90	
14.07.1998	10:41:00	0.000	132.08	
14.07.1998	11:11:00	0.000	132.38	
14.07.1998	11:41:00	0.000	132.78	
14.07.1998	12:11:00	0.000	133.14	
14.07.1998	13:11:00	0.000	133.60	
14.07.1998	14:11:00	0.000	134.13	
14.07.1998	15:11:00	0.000	134.60	
14.07.1998	16:11:00	0.000	135.01	
14.07.1998	17:11:00	0.000	135.37	
14.07.1998	18:11:00	0.000	135.79	
14.07.1998	19:11:00	0.000	136.05	137.3
24.07.1998	08:00:00	0.000	142.50	140.3
24.07.1998	08:00:00	0.010		
24.07.1998	09:00:00	0.010	140.71	138.7
24.07.1998	10:00:00	0.010	140.04	138.2
24.07.1998	14:15:00	0.010	138.61	136.8
24.07.1998	20:15:00	0.010	137.19	
25.07.1998	00:15:00	0.010	136.46	
25.07.1998	04:15:00	0.010	135.84	
25.07.1998	06:15:00	0.010	135.57	
25.07.1998	10:15:00	0.010	135.07	
25.07.1998	14:15:00	0.010	134.68	132.9
25.07.1998	16:15:00	0.010	134.48	
25.07.1998	20:15:00	0.010	134.10	132.4
26.07.1998	00:15:00	0.010	133.73	
26.07.1998	02:15:00	0.010	133.56	131.9
26.07.1998	06:15:00	0.010	133.25	
26.07.1998	10:15:00	0.010	132.99	
26.07.1998	14:15:00	0.010	132.75	131.0
26.07.1998	15:15:00	0.010	132.69	
26.07.1998	18:15:00	0.010	132.52	
26.07.1998	20:15:00	0.010	132.40	130.7
27.07.1998	00:15:00	0.010	132.18	
27.07.1998	02:15:00	0.010	132.08	130.4
27.07.1998	04:15:00	0.010	131.98	
27.07.1998	05:15:00	0.010	131.94	
27.07.1998	08:15:00	0.010	131.84	130.1
27.07.1998	12:15:00	0.010	131.64	
27.07.1998	14:15:00	0.010	131.55	129.9
27.07.1998	18:15:00	0.010	131.39	
27.07.1998	20:15:00	0.010	131.31	129.6
28.07.1998	00:15:00	0.010	131.16	
28.07.1998	02:15:00	0.010	131.09	129.4
28.07.1998	05:15:00	0.010	130.99	
28.07.1998	08:15:00	0.010	130.90	129.2
28.07.1998	12:15:00	0.010	130.79	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m ³ /s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
28.07.1998	14:15:00	0.010	130.74	
28.07.1998	18:15:00	0.010	130.63	
28.07.1998	20:15:00	0.010	130.57	128.9
29.07.1998	00:15:00	0.010	130.46	
29.07.1998	02:15:00	0.010	130.41	128.8
29.07.1998	05:15:00	0.010	130.34	
29.07.1998	08:15:00	0.010	130.28	128.6
29.07.1998	12:15:00	0.010	130.20	
29.07.1998	14:15:00	0.010	130.12	128.5
29.07.1998	16:15:00	0.010	130.10	
29.07.1998	18:15:00	0.010	130.09	
29.07.1998	20:15:00	0.010	130.05	128.4
30.07.1998	00:15:00	0.010	129.97	
30.07.1998	02:15:00	0.010	129.94	128.3
30.07.1998	05:15:00	0.010	129.88	
30.07.1998	08:15:00	0.010	129.82	
30.07.1998	14:15:00	0.010	129.73	128.1
30.07.1998	18:15:00	0.010	129.68	
30.07.1998	20:15:00	0.010	129.64	128.0
31.07.1998	00:15:00	0.010	129.57	
31.07.1998	02:15:00	0.010	129.52	127.9
31.07.1998	05:15:00	0.010	129.49	
31.07.1998	07:00:00	0.010		
31.07.1998	07:05:00	0.010	129.46	
31.07.1998	07:05:00	0.010		
31.07.1998	08:05:00	0.010	128.83	
31.07.1998	09:05:00	0.010	128.66	
31.07.1998	10:05:00	0.010	128.44	
31.07.1998	11:05:00	0.010	128.30	
31.07.1998	12:05:00	0.010	128.13	
31.07.1998	13:05:00	0.010	127.98	
31.07.1998	14:05:00	0.010	127.84	126.2
31.07.1998	16:05:00	0.010	127.58	
31.07.1998	18:05:00	0.010	127.35	
31.07.1998	20:05:00	0.010	127.13	125.6
01.08.1998	00:05:00	0.010	126.74	
01.08.1998	02:05:00	0.010	126.56	125.0
01.08.1998	05:05:00	0.010	126.31	
01.08.1998	08:05:00	0.010	126.08	124.5
01.08.1998	12:05:00	0.010	125.83	
01.08.1998	14:05:00	0.010	125.71	124.2
01.08.1998	16:05:00	0.010	125.58	
01.08.1998	20:05:00	0.010	125.33	123.8
02.08.1998	00:05:00	0.010	125.09	
02.08.1998	02:05:00	0.010	124.99	123.5
02.08.1998	05:05:00	0.010	124.82	
02.08.1998	08:05:00	0.010	124.67	123.2
02.08.1998	12:05:00	0.010	124.48	
02.08.1998	14:05:00	0.010	124.41	122.9
02.08.1998	16:05:00	0.010	124.32	
02.08.1998	18:05:00	0.010	124.23	
02.08.1998	20:05:00	0.010	124.14	122.6
03.08.1998	00:05:00	0.010	123.97	
03.08.1998	02:05:00	0.010	123.89	122.4
03.08.1998	05:05:00	0.010	123.77	
03.08.1998	08:05:00	0.010	123.66	122.2
03.08.1998	12:05:00	0.010	123.53	
03.08.1998	14:05:00	0.010	123.48	122.0
03.08.1998	16:05:00	0.010	123.46	
03.08.1998	20:05:00	0.010	123.43	122.0
04.08.1998	00:05:00	0.010	123.42	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
04.08.1998	02:05:00	0.010	123.42	122.0
04.08.1998	05:05:00	0.010	123.41	
04.08.1998	08:05:00	0.010	123.40	122.0
04.08.1998	10:05:00	0.010	123.40	
04.08.1998	14:05:00	0.010	123.40	122.0
04.08.1998	16:05:00	0.010	123.39	
04.08.1998	20:05:00	0.010	123.35	121.9
05.08.1998	00:05:00	0.010	123.29	
05.08.1998	02:05:00	0.010	123.26	121.9
05.08.1998	05:05:00	0.010	123.20	121.8
05.08.1998	08:05:00	0.010	123.14	121.7
05.08.1998	12:05:00	0.010	123.09	
05.08.1998	14:05:00	0.010	123.07	121.7
05.08.1998	16:05:00	0.010	123.05	
05.08.1998	20:05:00	0.010	122.98	121.6
06.08.1998	00:05:00	0.010	122.91	
06.08.1998	02:05:00	0.010	122.88	121.5
06.08.1998	05:05:00	0.010	122.84	
06.08.1998	08:05:00	0.010	122.80	121.4
06.08.1998	12:05:00	0.010	122.76	
06.08.1998	14:05:00	0.010	122.74	
06.08.1998	16:05:00	0.010	122.71	
06.08.1998	20:05:00	0.010	122.67	121.3
07.08.1998	00:05:00	0.010	122.58	
07.08.1998	02:05:00	0.010	122.56	
07.08.1998	05:05:00	0.010	122.51	
07.08.1998	06:05:00	0.010	122.51	121.1
07.08.1998	08:05:00	0.010	122.30	
07.08.1998	12:05:00	0.010	122.43	
07.08.1998	14:05:00	0.010	122.42	
07.08.1998	16:05:00	0.010	122.39	
07.08.1998	20:05:00	0.010	122.32	121.0
08.08.1998	00:05:00	0.010	122.24	
08.08.1998	02:05:00	0.010	122.22	
08.08.1998	06:05:00	0.010	122.20	
08.08.1998	07:05:00	0.010	122.18	120.9
08.08.1998	10:05:00	0.010	122.08	
08.08.1998	12:05:00	0.010	122.12	
08.08.1998	14:05:00	0.010	122.10	120.9
08.08.1998	16:05:00	0.010	122.06	
08.08.1998	20:05:00	0.010	122.01	120.9
09.08.1998	00:05:00	0.010	121.94	
09.08.1998	02:05:00	0.010	121.91	
09.08.1998	05:05:00	0.010	121.89	120.9
09.08.1998	07:05:00	0.010	121.87	
09.08.1998	08:05:00	0.010	121.84	
09.08.1998	12:05:00	0.010	121.80	
09.08.1998	14:05:00	0.010	121.78	
09.08.1998	16:05:00	0.010	121.75	120.9
09.08.1998	19:05:00	0.010	121.70	120.8
09.08.1998	20:05:00	0.010	121.68	
10.08.1998	00:05:00	0.010	121.64	
10.08.1998	02:05:00	0.010	121.62	
10.08.1998	05:05:00	0.010	121.58	
10.08.1998	06:05:00	0.010	121.57	120.8
10.08.1998	07:05:00	0.010	121.55	
10.08.1998	08:05:00	0.010	121.55	
10.08.1998	09:05:00	0.010	121.53	
10.08.1998	10:05:00	0.010	121.51	
10.08.1998	11:05:00	0.010	121.51	
10.08.1998	12:05:00	0.010	121.49	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
10.08.1998	13:05:00	0.008	121.49	
10.08.1998	14:05:00	0.008	121.49	
10.08.1998	15:05:00	0.008	121.49	
10.08.1998	16:05:00	0.008	121.48	290.0
10.08.1998	17:05:00	0.008	121.46	
10.08.1998	18:05:00	0.008	121.46	
10.08.1998	19:05:00	0.008	121.46	
10.08.1998	20:05:00	0.008	121.42	
10.08.1998	21:05:00	0.008	121.41	
10.08.1998	22:05:00	0.008	121.40	
10.08.1998	23:05:00	0.008	121.39	
11.08.1998	00:05:00	0.008	121.38	287.0
11.08.1998	01:05:00	0.008	121.38	
11.08.1998	02:05:00	0.008	121.38	
11.08.1998	03:05:00	0.008	121.36	
11.08.1998	04:05:00	0.008	121.34	289.0
11.08.1998	05:05:00	0.008	121.32	
11.08.1998	06:05:00	0.008	121.30	
11.08.1998	07:21:00	0.008	121.29	
11.08.1998	07:22:00	0.009	121.24	
11.08.1998	07:23:00	0.010	121.18	
11.08.1998	07:24:00	0.012	120.99	
11.08.1998	07:25:00	0.012	121.09	
11.08.1998	07:26:00	0.012	120.91	
11.08.1998	07:27:00	0.012	120.83	
11.08.1998	07:28:00	0.012	120.84	
11.08.1998	07:29:00	0.012	120.82	
11.08.1998	07:30:00	0.012	120.79	
11.08.1998	07:31:00	0.012	120.80	
11.08.1998	07:33:00	0.012	120.78	
11.08.1998	07:35:00	0.012	120.76	
11.08.1998	07:37:00	0.012	120.74	
11.08.1998	07:39:00	0.012	120.73	
11.08.1998	07:41:00	0.012	120.71	
11.08.1998	07:46:00	0.012	120.69	
11.08.1998	07:51:00	0.012	120.66	
11.08.1998	07:56:00	0.012	120.63	
11.08.1998	08:01:00	0.012	120.60	289.0
11.08.1998	08:11:00	0.012	120.55	
11.08.1998	08:21:00	0.012	120.48	
11.08.1998	08:31:00	0.012	120.40	
11.08.1998	08:41:00	0.012	120.30	
11.08.1998	08:51:00	0.012	120.17	
11.08.1998	09:21:00	0.012	119.82	
11.08.1998	09:51:00	0.012	119.25	
11.08.1998	10:21:00	0.012	118.80	
11.08.1998	11:21:00	0.012	118.17	
11.08.1998	12:21:00	0.012	117.19	317.0
11.08.1998	13:21:00	0.012	116.14	
11.08.1998	14:21:00	0.012	115.45	
11.08.1998	15:21:00	0.012	114.91	
11.08.1998	16:21:00	0.012	114.21	315.0
11.08.1998	17:21:00	0.012	113.50	
11.08.1998	18:21:00	0.012	113.25	
11.08.1998	19:21:00	0.012	113.03	
11.08.1998	20:21:00	0.012	112.59	297.0
11.08.1998	21:21:00	0.012	112.11	
11.08.1998	22:21:00	0.012	110.79	
11.08.1998	23:21:00	0.012	105.89	
12.08.1998	00:21:00	0.012	101.99	301.0
12.08.1998	01:21:00	0.012	97.11	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
12.08.1998	02:21:00	0.010	97.66	
12.08.1998	02:22:00	0.010	98.09	
12.08.1998	02:23:00	0.010	98.27	
12.08.1998	02:24:00	0.010	98.54	
12.08.1998	02:25:00	0.010	98.66	
12.08.1998	02:26:00	0.010	98.78	
12.08.1998	02:27:00	0.010	98.91	
12.08.1998	02:28:00	0.010	99.02	
12.08.1998	02:29:00	0.010	99.15	
12.08.1998	02:30:00	0.010	99.40	
12.08.1998	02:31:00	0.010	99.38	
12.08.1998	02:33:00	0.010	99.42	
12.08.1998	02:35:00	0.010	99.44	
12.08.1998	02:37:00	0.010	99.45	
12.08.1998	02:39:00	0.010	99.45	
12.08.1998	02:41:00	0.010	99.43	
12.08.1998	02:46:00	0.010	99.38	
12.08.1998	02:51:00	0.010	99.29	
12.08.1998	02:55:00	0.010	99.07	
12.08.1998	03:01:00	0.010	98.96	
12.08.1998	03:11:00	0.010	98.69	
12.08.1998	03:21:00	0.010	98.46	
12.08.1998	03:31:00	0.010	98.18	
12.08.1998	03:41:00	0.010	97.92	
12.08.1998	03:51:00	0.010	97.71	
12.08.1998	04:21:00	0.010	97.59	
12.08.1998	04:51:00	0.010	97.48	
12.08.1998	05:21:00	0.010	97.39	
12.08.1998	05:51:00	0.010	97.22	
12.08.1998	06:21:00	0.010	97.07	
12.08.1998	07:00:00	0.008	100.18	
12.08.1998	07:01:00	0.008	100.59	
12.08.1998	07:02:00	0.008	100.83	
12.08.1998	07:03:00	0.008	101.46	
12.08.1998	07:04:00	0.008	101.88	
12.08.1998	07:05:00	0.008	102.21	
12.08.1998	07:06:00	0.008	102.72	
12.08.1998	07:07:00	0.008	103.24	
12.08.1998	07:08:00	0.008	103.78	
12.08.1998	07:10:00	0.008	104.67	
12.08.1998	07:12:00	0.008	105.48	
12.08.1998	07:14:00	0.008	106.08	
12.08.1998	07:16:00	0.008	106.69	
12.08.1998	07:18:00	0.008	107.29	
12.08.1998	07:20:00	0.008	107.78	
12.08.1998	07:25:00	0.008	109.01	
12.08.1998	07:30:00	0.008	109.78	
12.08.1998	07:35:00	0.008	110.83	
12.08.1998	07:40:00	0.008	112.59	
12.08.1998	07:50:00	0.008	113.64	
12.08.1998	08:00:00	0.009	114.58	
12.08.1998	08:01:00	0.009	114.49	
12.08.1998	08:02:00	0.010	114.42	
12.08.1998	08:03:00	0.010	114.05	
12.08.1998	08:04:00	0.010	113.73	
12.08.1998	08:05:00	0.010	113.49	
12.08.1998	08:06:00	0.010	113.31	
12.08.1998	08:07:00	0.010	113.16	
12.08.1998	08:08:00	0.010	113.04	
12.08.1998	08:09:00	0.010	112.93	
12.08.1998	08:10:00	0.010	112.84	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Wellbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Wellbach (Pumpbrunnen)
 und am alten Brunnen Wellbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
12.08.1998	08:12:00	0.010	112.68	
12.08.1998	08:14:00	0.010	112.58	
12.08.1998	08:16:00	0.010	112.51	
12.08.1998	08:18:00	0.010	112.46	
12.08.1998	08:20:00	0.010	112.42	
12.08.1998	08:25:00	0.010	112.36	
12.08.1998	08:30:00	0.010	112.31	
12.08.1998	08:35:00	0.010	112.27	
12.08.1998	08:40:00	0.010	112.24	
12.08.1998	08:50:00	0.010	112.22	
12.08.1998	09:00:00	0.010	112.20	
12.08.1998	09:10:00	0.010	112.19	
12.08.1998	09:20:00	0.010	112.17	
12.08.1998	09:30:00	0.010	112.15	
12.08.1998	10:00:00	0.010	112.13	
12.08.1998	10:30:00	0.010	112.10	
12.08.1998	11:00:00	0.010	112.07	
12.08.1998	12:00:00	0.010	112.03	
12.08.1998	13:00:00	0.010	111.98	
12.08.1998	14:00:00	0.010	111.94	
12.08.1998	15:00:00	0.010	111.87	
12.08.1998	16:00:00	0.010	111.81	
12.08.1998	17:00:00	0.010	111.60	
12.08.1998	18:00:00	0.010	110.70	
12.08.1998	19:00:00	0.010	110.10	
12.08.1998	20:00:00	0.010	109.56	
12.08.1998	21:00:00	0.010	109.08	
12.08.1998	22:00:00	0.010	108.46	
12.08.1998	23:00:00	0.010	107.77	
13.08.1998	00:00:00	0.010	107.06	
13.08.1998	01:00:00	0.010	106.61	
13.08.1998	02:00:00	0.010	106.07	
13.08.1998	03:00:00	0.010	105.50	
13.08.1998	04:00:00	0.010	104.92	
13.08.1998	05:00:00	0.010	104.25	
13.08.1998	06:00:00	0.010	103.65	
13.08.1998	07:00:00	0.010	103.34	
13.08.1998	08:00:00	0.010	102.69	
13.08.1998	08:21:00	0.010	102.25	
13.08.1998	08:22:00	0.008	102.76	
13.08.1998	08:23:00	0.008	104.14	
13.08.1998	08:24:00	0.008	105.32	
13.08.1998	08:25:00	0.008	106.38	
13.08.1998	08:26:00	0.008	107.40	
13.08.1998	08:27:00	0.008	108.38	
13.08.1998	08:28:00	0.008	109.32	
13.08.1998	08:29:00	0.008	110.21	
13.08.1998	08:30:00	0.008	111.11	
13.08.1998	08:31:00	0.008	111.82	
13.08.1998	08:33:00	0.008	112.29	
13.08.1998	08:35:00	0.008	112.68	
13.08.1998	08:37:00	0.008	112.95	
13.08.1998	08:39:00	0.008	113.14	
13.08.1998	08:41:00	0.008	113.28	
13.08.1998	08:46:00	0.008	113.45	
13.08.1998	08:51:00	0.008	113.60	
13.08.1998	08:56:00	0.008	113.69	
13.08.1998	09:01:00	0.008	113.74	
13.08.1998	09:11:00	0.008	113.79	
13.08.1998	09:21:00	0.008	113.85	
13.08.1998	09:31:00	0.008	113.88	

**Sicherung der TwVorsorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m ³ /s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
13.08.1998	09:41:00	0.010	113.90	
13.08.1998	09:51:00	0.010	113.93	
13.08.1998	10:21:00	0.010	113.96	
13.08.1998	10:51:00	0.010	114.01	
13.08.1998	11:21:00	0.010	114.04	
13.08.1998	12:21:00	0.010	114.06	
13.08.1998	13:21:00	0.010	114.11	
13.08.1998	14:21:00	0.010	114.15	
13.08.1998	15:21:00	0.010	114.18	
13.08.1998	16:21:00	0.010	114.20	
13.08.1998	17:21:00	0.010	114.22	
13.08.1998	18:21:00	0.010	114.24	
13.08.1998	19:21:00	0.010	114.25	
13.08.1998	20:21:00	0.010	114.25	
13.08.1998	21:21:00	0.010	114.27	
13.08.1998	22:21:00	0.010	114.27	
13.08.1998	23:21:00	0.010	114.28	
14.08.1998	00:21:00	0.010	114.28	
14.08.1998	01:21:00	0.010	114.30	
14.08.1998	02:21:00	0.010	114.31	
14.08.1998	03:21:00	0.010	114.32	
14.08.1998	04:21:00	0.010	114.35	
14.08.1998	05:21:00	0.010	114.37	
14.08.1998	06:21:00	0.010	114.42	
14.08.1998	07:21:00	0.010	114.48	
14.08.1998	08:21:00	0.010	114.53	118.9
14.08.1998	09:21:00	0.010	114.58	
14.08.1998	10:21:00	0.010	114.62	
14.08.1998	11:21:00	0.010	114.66	
14.08.1998	12:21:00	0.010	114.72	
14.08.1998	13:21:00	0.010	114.76	
14.08.1998	14:21:00	0.010	114.88	118.9
14.08.1998	15:21:00	0.010	114.91	
14.08.1998	16:21:00	0.010	114.97	
14.08.1998	17:21:00	0.010	114.91	
14.08.1998	18:21:00	0.010	115.04	
14.08.1998	19:21:00	0.010	115.05	
14.08.1998	20:21:00	0.010	115.10	119.0
14.08.1998	21:21:00	0.010	115.12	
14.08.1998	22:21:00	0.010	115.14	
14.08.1998	23:21:00	0.010	115.17	
15.08.1998	00:21:00	0.010	115.21	119.1
15.08.1998	01:21:00	0.010	115.23	
15.08.1998	02:21:00	0.010	115.26	
15.08.1998	03:21:00	0.010	115.28	
15.08.1998	04:21:00	0.010	115.31	
15.08.1998	05:21:00	0.010	115.33	
15.08.1998	06:21:00	0.010	115.39	
15.08.1998	07:21:00	0.010	115.42	
15.08.1998	08:29:00	0.010	115.44	119.1
15.08.1998	09:21:00	0.010	115.49	
15.08.1998	10:21:00	0.010	115.52	
15.08.1998	11:21:00	0.010	115.56	
15.08.1998	12:21:00	0.010	115.59	
15.08.1998	13:21:00	0.010	115.64	
15.08.1998	14:21:00	0.010	115.68	119.2
15.08.1998	15:21:00	0.010	115.70	
15.08.1998	16:21:00	0.008	115.73	
15.08.1998	17:21:00	0.010	115.74	
15.08.1998	18:21:00	0.010	115.76	
15.08.1998	19:21:00	0.010	115.77	

**Sicherung der TwVorsorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
15.08.1998	20:21:00	0.010	115.79	119.2
15.08.1998	21:21:00	0.010	115.80	
15.08.1998	22:21:00	0.010	115.82	
15.08.1998	23:21:00	0.010	115.83	
16.08.1998	00:21:00	0.010	115.85	
16.08.1998	01:21:00	0.010	115.86	
16.08.1998	02:21:00	0.010	115.87	119.2
16.08.1998	03:21:00	0.010	115.89	
16.08.1998	04:21:00	0.010	115.90	
16.08.1998	05:21:00	0.010	115.91	
16.08.1998	06:21:00	0.010	115.93	
16.08.1998	07:21:00	0.010	115.94	
16.08.1998	08:21:00	0.010	115.96	119.2
16.08.1998	09:21:00	0.010	115.99	
16.08.1998	10:21:00	0.010	116.01	
16.08.1998	11:22:00	0.010	116.03	
16.08.1998	12:21:00	0.010	116.06	
16.08.1998	13:21:00	0.010	116.07	
16.08.1998	14:21:00	0.010	116.07	119.2
16.08.1998	15:21:00	0.010	116.08	
16.08.1998	16:21:00	0.010	116.09	
16.08.1998	17:21:00	0.010	116.11	
16.08.1998	18:21:00	0.010	116.11	
16.08.1998	19:21:00	0.010	116.11	
16.08.1998	20:21:00	0.010	116.11	119.2
16.08.1998	21:21:00	0.010	116.12	
16.08.1998	22:21:00	0.010	116.12	
16.08.1998	23:21:00	0.010	116.13	
17.08.1998	00:21:00	0.010	116.13	
17.08.1998	01:21:00	0.010	116.14	
17.08.1998	02:21:00	0.010	116.14	119.2
17.08.1998	03:21:00	0.010	116.14	
17.08.1998	04:21:00	0.010	116.15	
17.08.1998	05:21:00	0.010	116.16	
17.08.1998	05:21:00	0.010	116.19	
17.08.1998	06:21:00	0.010	116.19	
17.08.1998	07:21:00	0.010	116.21	
17.08.1998	08:21:00	0.010	116.21	119.2
17.08.1998	09:21:00	0.010	116.22	
17.08.1998	10:21:00	0.010	116.23	
17.08.1998	11:21:00	0.010	116.26	
17.08.1998	12:21:00	0.010	116.29	
17.08.1998	13:21:00	0.010	116.31	
17.08.1998	14:21:00	0.010	116.32	119.2
17.08.1998	15:21:00	0.010	116.33	
17.08.1998	16:21:00	0.010	116.35	
17.08.1998	17:21:00	0.010	116.37	
17.08.1998	18:21:00	0.010	116.37	
17.08.1998	19:21:00	0.010	116.35	
17.08.1998	20:21:00	0.010	116.33	119.2
17.08.1998	21:21:00	0.010	116.33	
17.08.1998	22:21:00	0.010	116.31	
17.08.1998	23:21:00	0.010	116.31	
18.08.1998	00:21:00	0.010	116.31	
18.08.1998	01:21:00	0.010	116.31	
18.08.1998	02:21:00	0.010	116.31	119.2
18.08.1998	03:21:00	0.010	116.31	
18.08.1998	04:21:00	0.008	116.31	
18.08.1998	05:21:00	0.010	116.31	
18.08.1998	06:21:00	0.010	116.34	
18.08.1998	07:21:00	0.010	116.35	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
18.08.1998	08:21:00	0.010	116.36	119.2
18.08.1998	09:21:00	0.010	116.36	
18.08.1998	10:21:00	0.010	116.37	
18.08.1998	11:21:00	0.010	116.38	
18.08.1998	12:21:00	0.010	116.39	
18.08.1998	13:21:00	0.010	116.41	
18.08.1998	14:21:00	0.010	116.43	119.2
18.08.1998	15:21:00	0.010	116.44	
18.08.1998	16:21:00	0.010	116.46	
18.08.1998	17:21:00	0.010	116.46	
18.08.1998	18:21:00	0.010	116.46	
18.08.1998	19:21:00	0.010	116.46	
18.08.1998	20:21:00	0.010	116.46	119.2
18.08.1998	21:21:00	0.010	116.46	
18.08.1998	22:21:00	0.010	116.46	
18.08.1998	23:21:00	0.010	116.45	
19.08.1998	00:21:00	0.010	116.45	
19.08.1998	01:21:00	0.010	116.45	
19.08.1998	02:21:00	0.010	116.44	119.3
19.08.1998	03:21:00	0.010	116.45	
19.08.1998	04:21:00	0.010	116.45	
19.08.1998	05:21:00	0.010	116.45	
19.08.1998	06:21:00	0.010	116.45	
19.08.1998	07:21:00	0.010	116.44	
19.08.1998	08:21:00	0.010	116.45	119.3
19.08.1998	09:21:00	0.010	116.45	
19.08.1998	10:21:00	0.010	116.46	
19.08.1998	11:21:00	0.010	116.47	
19.08.1998	12:21:00	0.010	116.48	
19.08.1998	13:21:00	0.010	116.48	
19.08.1998	14:21:00	0.010	116.49	119.3
19.08.1998	15:21:00	0.010	116.50	
19.08.1998	16:21:00	0.010	116.50	
19.08.1998	17:21:00	0.010	116.51	
19.08.1998	18:21:00	0.010	116.51	
19.08.1998	19:21:00	0.010	116.51	
19.08.1998	20:21:00	0.010	116.52	119.3
19.08.1998	21:21:00	0.010	116.50	
19.08.1998	22:21:00	0.010	116.50	
19.08.1998	23:21:00	0.010	116.50	
20.08.1998	00:21:00	0.010	116.49	
20.08.1998	01:21:00	0.010	116.48	
20.08.1998	02:21:00	0.010	116.49	119.3
20.08.1998	03:21:00	0.010	116.48	
20.08.1998	04:21:00	0.010	116.48	
20.08.1998	05:21:00	0.010	116.48	
20.08.1998	06:21:00	0.010	116.48	
20.08.1998	07:21:00	0.010	116.48	
20.08.1998	08:21:00	0.010	116.48	119.3
20.08.1998	09:21:00	0.010	116.49	
20.08.1998	10:21:00	0.010	116.50	
20.08.1998	11:21:00	0.010	116.51	
20.08.1998	12:21:00	0.010	116.51	
20.08.1998	13:21:00	0.010	116.53	
20.08.1998	14:21:00	0.010	116.52	119.3
20.08.1998	15:21:00	0.010	116.53	
20.08.1998	16:21:00	0.010	116.54	
20.08.1998	17:21:00	0.008	116.54	
20.08.1998	18:21:00	0.010	116.55	
20.08.1998	19:21:00	0.010	116.55	
20.08.1998	20:21:00	0.010	116.54	119.3

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
20.08.1998	21:21:00	0.010	116.54	
20.08.1998	22:21:00	0.010	116.53	
20.08.1998	23:21:00	0.010	116.52	
21.08.1998	00:21:00	0.010	116.52	
21.08.1998	01:21:00	0.010	116.51	
21.08.1998	02:21:00	0.010	116.51	119.3
21.08.1998	03:21:00	0.010	116.51	
21.08.1998	04:21:00	0.010	116.51	
21.08.1998	05:21:00	0.010	116.51	
21.08.1998	06:21:00	0.010	116.51	
21.08.1998	07:00:00	0.010	116.80	
21.08.1998	07:00:00	0.000	116.80	
21.08.1998	07:01:00	0.000	118.24	
21.08.1998	07:02:00	0.000	119.25	
21.08.1998	07:03:00	0.000	119.92	
21.08.1998	07:04:00	0.000	120.29	
21.08.1998	07:05:00	0.000	120.36	
21.08.1998	07:06:00	0.000	120.38	
21.08.1998	07:07:00	0.000	120.40	
21.08.1998	07:08:00	0.000	120.41	
21.08.1998	07:09:00	0.000	120.43	
21.08.1998	07:10:00	0.000	120.44	
21.08.1998	07:12:00	0.000	120.45	
21.08.1998	07:14:00	0.000	120.47	
21.08.1998	07:16:00	0.000	120.48	
21.08.1998	07:18:00	0.000	120.50	
21.08.1998	07:20:00	0.000	120.51	
21.08.1998	07:25:00	0.000	120.52	
21.08.1998	07:30:00	0.000	120.54	
21.08.1998	07:35:00	0.000	120.57	
21.08.1998	07:40:00	0.000	120.59	
21.08.1998	07:50:00	0.000	120.64	
21.08.1998	08:00:00	0.000	120.68	119.3
21.08.1998	08:10:00	0.000	120.72	
21.08.1998	08:20:00	0.000	120.76	
21.08.1998	08:30:00	0.000	120.80	120.8
21.08.1998	09:00:00	0.000	120.88	120.9
21.08.1998	09:30:00	0.000	121.00	120.9
21.08.1998	10:00:00	0.000	121.12	121.0
21.08.1998	11:00:00	0.000	121.29	121.1
21.08.1998	12:00:00	0.000	121.55	121.4
21.08.1998	13:00:00	0.000	121.80	121.6
21.08.1998	14:00:00	0.000	122.08	121.9
21.08.1998	15:00:00	0.000	122.41	122.1
21.08.1998	16:00:00	0.000	122.76	122.5
21.08.1998	17:00:00	0.000	123.08	
21.08.1998	18:00:00	0.000	123.38	
21.08.1998	19:00:00	0.000	123.62	
21.08.1998	20:00:00	0.000	123.90	123.9
21.08.1998	21:00:00	0.000	124.24	
21.08.1998	22:00:00	0.000	124.64	
21.08.1998	23:00:00	0.000	125.04	124.9
22.08.1998	00:00:00	0.000	125.41	
22.08.1998	01:00:00	0.000	125.74	
22.08.1998	02:00:00	0.000	126.07	
22.08.1998	03:00:00	0.000	126.40	
22.08.1998	04:00:00	0.000	126.73	
22.08.1998	05:00:00	0.000	127.07	
22.08.1998	06:00:00	0.000	127.39	127.0
22.08.1998	07:00:00	0.000	127.69	
22.08.1998	08:00:00	0.000	127.98	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
 Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
 und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
22.08.1998	09:00:00	0.000	128.27	
22.08.1998	10:00:00	0.000	128.56	
22.08.1998	11:00:00	0.000	128.87	
22.08.1998	12:00:00	0.000	129.16	128.6
22.08.1998	13:00:00	0.000	129.44	
22.08.1998	14:00:00	0.000	129.71	
22.08.1998	15:00:00	0.000	129.97	
22.08.1998	16:00:00	0.000	130.24	
22.08.1998	17:00:00	0.000	130.49	
22.08.1998	18:00:00	0.000	130.73	130.1
22.08.1998	19:00:00	0.000	130.97	
22.08.1998	20:00:00	0.000	131.22	
22.08.1998	21:00:00	0.000	131.46	
22.08.1998	22:00:00	0.000	131.70	131.0
22.08.1998	23:00:00	0.000	131.94	
23.08.1998	00:00:00	0.000	132.17	
23.08.1998	01:00:00	0.000	132.39	131.5
23.08.1998	02:00:00	0.000	132.61	
23.08.1998	03:00:00	0.000	132.82	
23.08.1998	04:00:00	0.000	133.03	
23.08.1998	05:00:00	0.000	133.23	
23.08.1998	06:00:00	0.000	133.43	132.5
23.08.1998	07:00:00	0.000	133.62	
23.08.1998	08:00:00	0.000	133.81	
23.08.1998	09:00:00	0.000	134.00	
23.08.1998	10:00:00	0.000	134.19	
23.08.1998	11:00:00	0.000	134.38	
23.08.1998	12:00:00	0.000	134.55	133.5
23.08.1998	13:00:00	0.000	134.73	
23.08.1998	14:00:00	0.000	134.91	
23.08.1998	15:00:00	0.000	135.08	
23.08.1998	16:00:00	0.000	135.25	
23.08.1998	17:00:00	0.000	135.42	
23.08.1998	18:00:00	0.000	135.59	134.4
23.08.1998	19:00:00	0.000	135.75	
23.08.1998	20:00:00	0.000	135.91	
23.08.1998	21:00:00	0.000	136.06	
23.08.1998	22:00:00	0.000	136.21	
23.08.1998	23:00:00	0.000	136.36	135.1
24.08.1998	00:00:00	0.000	136.51	
24.08.1998	01:00:00	0.000	136.65	
24.08.1998	02:00:00	0.000	136.79	
24.08.1998	03:00:00	0.000	136.93	
24.08.1998	04:00:00	0.000	137.07	
24.08.1998	05:00:00	0.000	137.21	
24.08.1998	06:00:00	0.000	137.33	136.0
24.08.1998	07:00:00	0.000	137.46	
24.08.1998	08:00:00	0.000	137.58	
24.08.1998	09:00:00	0.000	137.69	
24.08.1998	10:00:00	0.000	137.81	
24.08.1998	11:00:00	0.000	137.92	
24.08.1998	12:00:00	0.000	138.03	136.6
24.08.1998	13:00:00	0.000	138.14	
24.08.1998	14:00:00	0.000	138.25	
24.08.1998	15:00:00	0.000	138.35	
24.08.1998	16:00:00	0.000	138.45	
24.08.1998	17:00:00	0.000	138.55	
24.08.1998	18:00:00	0.000	138.65	137.13
24.08.1998	19:00:00	0.000	138.74	
24.08.1998	20:00:00	0.000	138.84	
24.08.1998	21:00:00	0.000	138.93	

**Sicherung der TwVersorgung von Miltenberg - Bürgstadt (EMB) und Weilbach
Pumpversuchsdaten des KPV und LPV am Brunnen I - neuer Brunnen Weilbach (Pumpbrunnen)
und am alten Brunnen Weilbach**

Datum	Uhrzeit	Förderrate m³/s	Wasserstand [mNN] - Br. I	Wasserstand [mNN] - Br. alt
24.08.1998	22:00:00	0.000	139.02	
24.08.1998	23:00:00	0.000	139.11	137.6
25.08.1998	00:00:00	0.000	139.19	
25.08.1998	01:00:00	0.000	139.28	
25.08.1998	02:00:00	0.000	139.36	
25.08.1998	03:00:00	0.000	139.45	
25.08.1998	04:00:00	0.000	139.53	
25.08.1998	05:00:00	0.000	139.61	
25.08.1998	06:00:00	0.000	139.69	138.1
25.08.1998	07:00:00	0.000	139.76	
25.08.1998	08:00:00	0.000	139.84	
25.08.1998	09:00:00	0.000	139.92	
25.08.1998	10:00:00	0.000	139.99	
25.08.1998	11:00:00	0.000	140.06	
25.08.1998	12:00:00	0.000	140.13	
25.08.1998	13:00:00	0.000	140.20	138.5
25.08.1998	14:00:00	0.000	140.27	
25.08.1998	15:00:00	0.000	140.34	
25.08.1998	16:00:00	0.000	140.40	
25.08.1998	17:00:00	0.000	140.47	
25.08.1998	18:00:00	0.000	140.53	138.8
25.08.1998	19:00:00	0.000	140.59	
25.08.1998	20:00:00	0.000	140.65	
25.08.1998	21:00:00	0.000	140.70	
25.08.1998	22:00:00	0.000	140.76	
25.08.1998	23:00:00	0.000	140.81	139.1
26.08.1998	00:00:00	0.000	140.87	
26.08.1998	01:00:00	0.000	140.92	
26.08.1998	02:00:00	0.000	140.97	
26.08.1998	03:00:00	0.000	141.02	
26.08.1998	04:00:00	0.000	141.07	
26.08.1998	05:00:00	0.000	141.12	
26.08.1998	06:00:00	0.000	141.17	139.4
26.08.1998	07:00:00	0.000	141.22	
27.08.1998	07:00:00	0.000	142.11	
27.08.1998	00:00:00	0.000		